

BUREAU VERITAS
Certification



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Certificate Nb: **1035-CPR-ES073955**

In compliance of the Regulation No 305/2011 of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of construction products, it has been stated that the product:

CONTAINER VALVE ASSEMBLIES AND THEIR ACTUATORS

Described in the table attached to this certificate,

Placed in the market and
produced by:

FLEXIMECAN, S.L.U.

C/ De la Tècnica, 83 – Sant Andreu de la Barca (Barcelona)

In its factory located in:

**1.- C/ De la Tècnica, 83 – Sant Andreu de la Barca
(Barcelona)**

is submitted by the manufacturer to a Factory Production Control and that notified body *Bureau Veritas Certification* has performed the Initial Type Tests in an accredited laboratory and the Initial Inspection of the Factory and Factory Production Control, the evaluation of conformity and performs the continuous surveillance, assessment and approval of the Factory Production Control described in the standard:

EN 12094-4:2004

This certificate attests that all the relative requirements for the compliance of the conformity described in the annex ZA of the harmonized standard were applied, that the product fulfils all the prescribed requirements and it authorizes the manufacturer or its agent to fix the CE marking.

This certificate remains valid while the conditions established in the harmonized standard or the production conditions of the factory or the same FPC have not changed significantly.

Date of first approval: **2016, October 17th**

Date of update: **2019, October 4th**

Valid until: **2022, October 16th**



Mónica Botas
Certification manager

Bureau Veritas Iberia, S.L., Edificio Caoba. C/ Valportillo Primera 22-24 Polígono Industrial La Granja, 28108 – Alcobendas (MADRID). Notified body 1035



ANNEX TO CERTIFICATE Nb° 1035-CPR- ES073955

Date: **2019, May 3rd**

| Model | Type of gas | Probe Tube | Nominal Diameter | Working pressure | Free Flow area | Actuator type | Smaller Container | Service Temp. |
|----------------------------------|----------------------------|------------|------------------|------------------|------------------------|-----------------------------|-------------------|---------------|
| FLEXIMECAN FLM 140 | CO2 | Yes | 11 mm. | 140 bar | 45,31 mm ² | Manual/Electrical | 3 dm ³ | -20°C +50°C |
| FLEXIMECAN FLM 150 | CO2 | Yes | 11 mm. | 140 bar | 45,31 mm ² | Pneumatic | 3 dm ³ | -20°C +50°C |
| FLEXIMECAN FLM 173 salida 1" | HFC-227ea | Yes | 25 mm. | 53 bar | 412,34 mm ² | Manual/Electrical/Pneumatic | 3 dm ³ | -20°C +50°C |
| FLEXIMECAN FLM 173 salida 1 1/4" | HFC-227ea | Yes | 25 mm. | 53 bar | 412,34 mm ² | Manual/Electrical/Pneumatic | 3 dm ³ | -20°C +50°C |
| FLEXIMECAN FLM 173 salida 1" | N ₂ + FK-5-1-12 | Yes | 25 mm. | 53 bar | 412,34 mm ² | Manual/Electrical/Pneumatic | 3 dm ³ | -20°C +50°C |
| FLEXIMECAN FLM 173 salida 1 1/4" | N ₂ + FK-5-1-12 | Yes | 25 mm. | 53 bar | 412,34 mm ² | Manual/Electrical/Pneumatic | 3 dm ³ | -20°C +50°C |